

Datasheet Sensiblue 315

Rev 06 date 2017.06.22



Flow	3 - 15 l / min , 150 – 900l/ h
Active Chlorine	0,20 – 0,40 mg / l
Max working pressure	8 Bar, prevent water hammer
Maintenance	Salt Refill required after 30.000 litre, use Sensiblue Refill units
Water inlet and outlet	3/4 " BSPT

Incoming water requirements for optimal production of active Chlorine:

pH	< 7,8
Prefiltration	100 micron (preferably 40 micron)
Hardness	< 30 dH , < 50 fH
Organics	KMnO4 < 5 ppm
Iron	< 0,2 ppm
Temperature	5 – 40 degree C

